

POSTAL CUSTOMER

City Hall
749 Main Street
Louisville CO 80027

2023 Annual Drinking Water Quality Report

For calender year 2022


Esta es información importante. Si no la pueden leer, necesitan que alguien se la traduzca.

Public Water System ID: CO0107487

Our Water Sources



LOUISVILLE RESERVOIR



SOUTH BOULDER CREEK

Our constant goal is to provide you with a safe and dependable supply of drinking water.

Please contact **Greg Venette** at **303-335-4608** with any questions or for public participation.

For more information visit: LouisvilleCO.gov/Water.

General Information

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791) or by visiting epa.gov/ground-water-and-drinking-water.

Some groups of people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and microbiological contaminants, call the EPA Safe Drinking Water Hotline at (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- **Microbial contaminants:** viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants:** salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides:** may come from a variety of sources, such as agriculture, urban storm water runoff, and residential uses.
- **Radioactive contaminants:** can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants:** including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, the Colorado Department of Public Health and Environment prescribes regulations limiting the amount of certain contaminants in water provided by public water systems.



Air Blowers at the Howard Berry Water Treatment Plant.

The Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Lead in Drinking Water

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. If you feel you are at risk, before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Greg Venette at 303-335-4608. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at epa.gov/safewater/lead.

Source Water Assessment and Protection (SWAP)

The Colorado Department of Public Health and Environment may have provided the city with a Source Water Assessment Report for our water supply. For general information or to obtain a copy of the report please visit: wqcdcompliance.com/ccr. The report is located under "Guidance: Source Water Assessment Reports". Search the table using system name or ID, or by contacting Greg Venette at 303-335-4608. The Source Water Assessment Report provides a screening-level evaluation of potential contamination that could occur. It does not mean that the contamination has or will occur. The City can use this information to evaluate the need to improve the current water treatment capabilities and prepare for future contamination threats. This can help the City ensure that quality finished water is delivered to your homes. In addition, the source water assessment results provide a starting point for developing a source water protection plan. Potential sources of contamination in our source water area are listed on the next page.

Please contact the City to learn more about what you can do to help protect your drinking water sources, any questions about the Drinking Water Quality Report, to learn more about the City drinking water system, or to attend scheduled public meetings. We want you, our valued customers, to be informed about the services the City provides and the quality water delivered every day.

2022 Test Results

The City of Louisville routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table(s) show all detections found in the period of January 1 to December 31, 2022 unless otherwise noted. The State of Colorado requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one year old. Violations and Formal Enforcement Actions, if any, are reported in the next section of this report.

Note: Only detected contaminants sampled within the last 5 years appear in this report. If no tables appear in this section then no contaminants were detected in the last round of monitoring.

TERMS AND ABBREVIATIONS

Maximum Contaminant Level (MCL) – The highest level of a contaminant allowed in drinking water.

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.

Health-Based – A violation of either a MCL or TT.

Non-Health-Based – A violation that is not a MCL or TT.

Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment and other regulatory requirements.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Contaminant Level Goal (MCLG) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Violation (No Abbreviation) – Failure to meet a Colorado Primary Drinking Water Regulation.

Formal Enforcement Action (No Abbreviation) – Escalated action taken by the State (due to the risk to public health, or number or severity of violations) to bring a non-compliant water system back into compliance.

Variance and Exemptions (V/E) – Department permission not to meet a MCL or treatment technique under certain conditions.

Gross Alpha (No Abbreviation) – Gross alpha particle activity compliance value. It includes radium-226, but excludes radon 222, and uranium.

Picocuries per liter (pCi/L) – Measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) – Measure of the clarity or cloudiness of water. Turbidity in excess of 5 NTU is just noticeable to the typical person.

Compliance Value (No Abbreviation) – Single or calculated value used to determine if regulatory contaminant level (e.g. MCL) is met. Examples of calculated values are the 90th Percentile, Running Annual Average (RAA) and Locational Running Annual Average (LRAA).

Average (x-bar) – Typical value.

Range (R) – Lowest value to the highest value.

Sample Size (n) – Number or count of values (i.e. number of water samples collected).

Parts per million = Milligrams per liter (ppm = mg/L) – One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion = Micrograms per liter (ppb = ug/L) – One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Not Applicable (N/A) – Does not apply or not available.

Level 1 Assessment – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Disinfectants Sampled in the Distribution System							
TT Requirement: At least 95% of samples per period (month or quarter) must be at least 0.2 ppm OR if sample size is less than 40 no more than 1 sample is below 0.2 ppm							
Typical Sources: Water additive used to control microbes							
Disinfectant	Time Period	Results	Number of Samples Below Level	Sample Size	TT Violation	MRDL	Typical Sources
Chlorine	December 2022	Lowest period percentage of samples meeting TT requirement: 100%	0	23	No	4.0 ppm	Water additive used to control microbes

Lead and Copper Sampled in the Distribution System							
Contaminant Name	Time Period	90th Percentile	Sample Size	90th Percentile AL	Sample Sites Above AL	90th Percentile AL Exceedance	Typical Sources
Copper (ppm)	06/01/2022 to 09/30/2022	0.03	31	1.3	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppm)	06/01/2022 to 09/30/2022	0.001	31	0.015	0	No	

Disinfection Byproducts Sampled in the Distribution System								
Contaminant Name	Year	Average	Range: Low – High	Sample Size	MCL	MCLG	MCL Violation	Typical Sources
Total Haloacetic Acids (HAA5)	2022	19.48	13.3 to 24.6	16	60	N/A	No	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM)	2022	35.74	20 to 53	16	80	N/A	No	Byproduct of drinking water disinfection
Chlorite	2022	0.09	0 to 0.44	12	1	0.8	No	Byproduct of drinking water disinfection

Summary of Turbidity Sampled at the Entry Point to the Distribution System					
Contaminant Name	Sample Date	Level Found	TT Requirement	TT Violation	Typical Sources
Turbidity	Date/Month: Jan	Highest single measurement: 0.25 NTU	Maximum 1 NTU for any single measurement	No	Soil Runoff
Turbidity	Month: Dec	Lowest monthly percentage of samples meeting TT requirement for our technology: 100%	In any month, at least 95% of samples must be less than 0.3 NTU	No	

Radionuclides Sampled at the Entry Point to the Distribution System								
Contaminant Name	Year	Average	Range Low – High	Sample Size	MCL	MCLG	MCL Violation	Typical Sources
Gross Alpha	2020	0.8	0.7 to 0.9	2	15	0	No	Erosion of natural deposits
Combined Radium	2020	1.2	0.8 to 1.6	2	5	0	No	

Inorganic Contaminants Sampled at the Entry Point to the Distribution System								
Contaminant Name	Year	Average	Range Low – High	Sample Size	MCL	MCLG	MCL Violation	Typical Sources
Barium (ppm)	2022	0.03	0.04	2	2	2	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride (ppm)	2022	0.72	0.66 to 0.77	2	4	4	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

VIOLATIONS, SIGNIFICANT DEFICIENCIES, AND FORMAL ENFORCEMENT ACTIONS: Health-Based Violations

Maximum contaminant level (MCL) violations: Test results for this contaminant show that the level was too high for the time period shown. Please read the information shown below about potential health effects for vulnerable populations. This is the same violation that we told you about in a past notice. We are evaluating, or we already completed an evaluation, to find the best way to reduce or remove the contaminant. If the solution will take an extended period of time, we will keep you updated with quarterly notices.

Treatment technique (TT) violations: We failed to complete an action that could affect water quality. Please read the information shown below about potential health effects for vulnerable populations. This is the same violation that we told you about in a past notice. We were required to meet a minimum operation/treatment standard, we were required to make upgrades to our system, or we were required to evaluate our system for potential sanitary defects, and we failed to do so in the time period shown below. If the solution will take an extended period of time, we will keep you updated with quarterly notices. **Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin, or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water.

Secondary Contaminants*					
*Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin, or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water.					
Contaminant Name	Year	Average	Range: Low – High	Sample Size	Secondary Standard
Sodium	2022	16.15	14.5 to 17.8	2	N/A

Unregulated Contaminants**

EPA has implemented the Unregulated Contaminant Monitoring Rule (UCMR) to collect data for contaminants that are suspected to be present in drinking water and do not have health-based standards set under the Safe Drinking Water Act. EPA uses the results of UCMR monitoring to learn about the occurrence of unregulated contaminants in drinking water and to decide whether or not these contaminants will be regulated in the future. The City performed monitoring and reported the analytical results of the monitoring to EPA in accordance with its Unregulated Contaminant Monitoring Rule (UCMR). Once EPA reviews the submitted results, the results are made available in the EPA's National Contaminant Occurrence Database (NCOD) (epa.gov/dwucmr/national-contaminant-occurrence-database-ncod) Consumers can review UCMR results by accessing the NCOD. Contaminants that were detected during our UCMR sampling and the corresponding analytical results are provided below.

Contaminant Name	Year	Average	Range: Low – High	Sample Size
Anatoxin-a (Ug/L)	2020	<0.0300	<0.0300	11
Cylindrospermopsin (Ug/L)	2020	<0.0900	<0.0900	11
Total Microcystins & Nodularins (Ug/L)	2020	<0.300	<0.300	11
CVTM (%CV)	2020	1.79	0.2 – 5.3	11

** More information about the contaminants that were included in UCMR monitoring can be found at: [drinktap.org/Water-Info/Whats-in-My-Water/Unregulated-Contaminant-Monitoring-Rule-UCMR](https://www.drinktap.org/Water-Info/Whats-in-My-Water/Unregulated-Contaminant-Monitoring-Rule-UCMR). Learn more about the EPA UCMR at: epa.gov/dwucmr/learn-about-unregulated-contaminant-monitoring-rule or contact the Safe Drinking Water Hotline at (800) 426-4791 or epa.gov/ground-water-and-drinking-water.

Name	Description	Time Period	Health Effects	Compliance Value	TT Level or MCL	Additional Violation Information
TURBIDITY	EXCEEDED TURBIDITY (CLOUDINESS) LEVELS FOR SURFACE WATER FILTRATION	12/01/2021 - 12/31/2021	Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-easing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.	0.3	TT	Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.
CHLORINE:	FAILURE TO MAINTAIN MINIMUM TREATMENT FOR SURFACE WATER FILTRATION AND DISINFECTION	12/01/2021 - 12/31/2021	Disinfected residual serves as one of the final barriers to protect public health. Lack of an adequate disinfected residual may increase the likelihood that disease-causing organisms are present.	0.20	TT	During the Marshall Fire, Louisville's water system experienced extreme demand from firefighting efforts. Despite the efforts to keep water pressure up for firefighting, the system continued to lose pressure as the fire damaged the system. One of the emergency measures taken to restore pressure to the system to assist firefighting efforts was to release untreated Marshall Reservoir water into the distribution system. These actions, which were focused on the prevention of loss of life and property, resulted in the failure to meet the Colorado Department of Public Health and Environment (CDPHE) requirements for filtration and disinfection. As an immediate response to untreated water entering the system, a boil water advisory was issued on 12/30/2021. The entire drinking water distribution system was flushed of this untreated water and water testing was conducted under CDPHE guidance. Test results provided the necessary verification that the water system was safe and the boil water advisory was lifted on 1/6/2022. Because this time period crossed over into 2022, it is required to be included in this notice. There is nothing you need to do at this time. The immediate responses related to the fire and boil order have addressed all issues.
CROSS CONNECTION RULE	FAILURE TO MEET CROSS CONNECTION CONTROL AND/OR BACKFLOW PREVENTION REQUIREMENTS - M617	10/21/2022 - 10/24/2022	The City had an inadequate backflow prevention and cross-connection control program. Uncontrolled cross connections can lead to inadvertent contamination of the drinking water. The City failed to ensure that failed assemblies were repaired within 120 days of notification.	TT	TT	In 2021 there were six (6) failed assemblies identified that were not repaired within 120 days of notification, the compliance testing ratio was 0.77, missing the requirement of 0.9, and a number of assemblies not tested in 2021 were not tested within 90-days of their use in 2022.
CROSS CONNECTION RULE	FAILURE TO MEET CROSS CONNECTION CONTROL AND/OR BACKFLOW PREVENTION REQUIREMENT - M614	10/21/2022 - 2/8/2023	The City had an inadequate backflow prevention and cross-connection control program. Uncontrolled cross connections can lead to inadvertent contamination of the drinking water. The City failed to ensure the testing requirements met the annual backflow assembly testing compliance ratio.	TT	TT	A public notice was sent on 11/17/2022 with additional information. The City has improved system processes for the monitoring and management of the Backflow and Cross-Connection Program. All 6 of the failed assemblies over 120 day's notification have been repaired. Assemblies not tested in 2021 have been tested, suspended or cross-connection removed.
CROSS CONNECTION RULE	FAILURE TO MEET CROSS CONNECTION CONTROL AND/OR BACKFLOW PREVENTION REQUIREMENTS - M611	10/21/2022 – 2/8/2023	The City has an inadequate backflow prevention and cross-connection control program. Uncontrolled cross connections can lead to inadvertent contamination of the drinking water. We failed to ensure the testing requirements were complete for assemblies that were not tested in 2021 within 90 days of their use in 2022.	TT	TT	There is nothing you need to do at this time. Water infrastructure is functioning properly and drinking water in Louisville is safe to drink.